



KenCom Public Safety Dispatch

1100 Cornell Lane, Yorkville, Illinois 60560

Phone (630) 553-0911

Fax (630) 553-9411

July 2, 2018

Request for Proposals

Emergency Generator

KenCom Public Safety Dispatch is soliciting proposals for an emergency diesel generator to be installed at a remote radio tower site in Kendall County at Montgomery water tower at 1070 Emerald Drive, Montgomery.

The proposal shall include the following:

- The generator shall be a 15 kw, 110/240 volt, single phase, to be operated off of an on-site diesel storage tank (supplied under this proposal). Generator shall be capable of delivering up to 60 amps at full load. Generator shall be equipped with an outdoor weather enclosure – generator will be located outdoors.
- Automatic generator transfer switch sized to match generator output (load), equipped with automatic generator exerciser (scheduled run-test) and dry alarm contact closures for major failures and generator run.
- A sufficiently sized diesel storage tank that would provide four uninterrupted days (or 96 continuous hours) of generator operation.
- All associated site work for installation (Any concrete pads required for the generator and diesel tank, including underground electrical service to the water tower site building from the generator).
- Diesel tank shall be under the generator.
- Thermostatically controlled block heater.

Proposal shall also include:

- All associated wiring and installation work for the generator and transfer switch.
- Final connection to the building commercial power.
- Acceptance testing on completion.

General Notes:

- Permitting shall not be included in proposal. Zoning and permitting to be done by owner.
- All spoils and construction debris shall be removed from the tower construction site area, and the site area will be restored as needed.

Proposal Instruction:

- Proposals shall be accepted by KenCom Public Safety Dispatch until 4:00 PM, Central Daylight Savings Time on July 18, 2018, at KenCom Public Safety Dispatch, 1100 Cornell Lane, Yorkville, IL 60560. The proposal shall be sealed in an envelope or mailing container and on the outside of the envelope or mailing container, clearly marked as “Proposal for Tower Site Generator.”
- Prevailing Rate of Wages – Contractor shall not pay less than the prevailing rates of wages as ascertained by the Illinois Department of Labor for Kendall County, Illinois to all laborers, workmen, and mechanics performing work under this contract, and shall comply with the requirements of the Illinois Wages of Employees on Public Works Act (820 ILCS 130/1-12).
- KenCom Public Safety Dispatch is a unit of local government and therefore is exempt from the Illinois sales tax and the Federal excise tax. Proposals shall not include any costs for these taxes.
- All prices should include both shipping, storage and delivery charges. These charges shall be freight (F.O.B.) to the project site.
- KenCom Public Safety Dispatch reserves the right to reject any or all proposals, to award a contract for all or a portion of the proposed work, waive informalities or technicalities in any proposal, and accept any proposal it deems to be in its best interest.